

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: November 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
11/01/2025	7.94	27.5	Yes
11/02/2025	7.79	26.5	Yes
11/03/2025	7.86	26.5	Yes
11/04/2025	7.85	25.8	Yes
11/05/2025	7.91	24.0	Yes
11/06/2025	7.91	23.5	Yes
11/07/2025	7.87	22.5	Yes
11/08/2025	7.88	23.0	Yes
11/09/2025	7.82	23.0	Yes
11/10/2025	7.87	22.5	Yes
11/11/2025	7.86	22.5	Yes
11/12/2025	7.86	23.0	Yes
11/13/2025	7.89	22.0	Yes
11/14/2025	7.95	24.0	Yes
11/15/2025	7.87	24.5	Yes
11/16/2025	7.88	25.0	Yes
11/17/2025	7.81	25.0	Yes
11/18/2025	7.87	25.0	Yes
11/19/2025	7.84	25.5	Yes
11/20/2025	7.91	25.5	Yes
11/21/2025	7.94	26.5	Yes
11/22/2025	7.98	26.5	Yes
11/23/2025	7.89	27.0	Yes
11/24/2025	7.91	28.0	Yes
11/25/2025	7.84	27.5	Yes
11/26/2025	7.80	26.5	Yes
11/27/2025	7.76	25.5	Yes
11/28/2025	7.99	24.5	Yes
11/29/2025	7.98	24.5	Yes
11/30/2025	7.87	23.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? ☒ Y N

Supervisor's Signature _____ Print Name Dave Trotter

Certification #: 058778 Phone (503) 635-0394

03-Dec-25