

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: December 2025

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
12/01/2025	7.88	23.5	Yes
12/02/2025	7.86	22.5	Yes
12/03/2025	8.00	24.0	Yes
12/04/2025	7.88	25.0	Yes
12/05/2025	8.02	24.5	Yes
12/06/2025	7.96	22.0	Yes
12/07/2025	7.89	20.0	Yes
12/08/2025	7.87	18.5	Yes
12/09/2025	7.87	18.5	Yes
12/10/2025	8.01	18.0	Yes
12/11/2025	7.89	15.5	Yes
12/12/2025	8.13	18.5	Yes
12/13/2025	7.97	18.5	Yes
12/14/2025	8.04	19.5	Yes
12/15/2025	7.98	21.0	Yes
12/16/2025	7.91	21.5	Yes
12/17/2025	7.93	22.0	Yes
12/18/2025	8.02	20.5	Yes
12/19/2025	8.03		Yes
12/20/2025			
12/21/2025			
12/22/2025	7.89	19.5	Yes
12/23/2025	7.99	19.5	Yes
12/24/2025	8.03	20.0	Yes
12/25/2025	7.89	20.0	Yes
12/26/2025	7.99	20.0	Yes
12/27/2025	8.01	21.0	Yes
12/28/2025	8.01	21.0	Yes
12/29/2025	7.96	21.0	Yes
12/30/2025	7.87	21.3	Yes
12/31/2025	7.94	22.5	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance?

☒ Y ☐ N

Supervisor's Signature

Print Name

Dave Trotter

Certification #: 058778

Phone (503) 635-0394

03-Jan-26