

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: January 2026

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
01/01/2026	7.87	22.0	Yes
01/02/2026	7.87	22.5	Yes
01/03/2026	7.93	24.0	Yes
01/04/2026	7.82	23.5	Yes
01/05/2026	7.95	23.0	Yes
01/06/2026	7.95	22.5	Yes
01/07/2026	7.96	21.5	Yes
01/08/2026	7.99	20.0	Yes
01/09/2026	7.89	20.5	Yes
01/10/2026	8.00	21.0	Yes
01/11/2026	7.77	21.5	Yes
01/12/2026	7.85	22.0	Yes
01/13/2026	7.94	23.0	Yes
01/14/2026	8.00	23.5	Yes
01/15/2026	7.90	24.0	Yes
01/16/2026	7.92	23.0	Yes
01/17/2026	7.91	24.0	Yes
01/18/2026	7.82	24.0	Yes
01/19/2026	7.82	23.5	Yes
01/20/2026	7.95	23.8	Yes
01/21/2026	7.89	24.5	Yes
01/22/2026	7.86	24.0	Yes
01/23/2026	7.82	24.5	Yes
01/24/2026	7.89	24.0	Yes
01/25/2026	7.83	26.0	Yes
01/26/2026	7.79	26.0	Yes
01/27/2026	7.80	26.8	Yes
01/28/2026	7.92	26.5	Yes
01/29/2026	8.00	26.5	Yes
01/30/2026	7.92	26.0	Yes
01/31/2026	7.89	26.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature _____ Print Name Dave Trotter

Certification #: 058778 Phone (503) 635-0394 02-Feb-26