

Lake Oswego - Tigard Water Supply, PWS 4101542

Water Quality Parameter Monitoring Form Lead and Copper Corrosion Control

Surface Water Quality Data - POE Alkalinity and pH Report

City of Lake Oswego - Water Treatment Plant

Report Month: February 2026

State Minimum = 7.2 pH

Date	Average Finished pH	Average Finished Alkalinity	Standard Met ?
02/01/2026	7.92	26.0	Yes
02/02/2026	7.89	25.8	Yes
02/03/2026	7.92	26.0	Yes
02/04/2026	7.91	26.0	Yes
02/05/2026	7.87	26.0	Yes
02/06/2026	7.91	26.5	Yes
02/07/2026	7.89	25.0	Yes
02/08/2026	7.86	25.0	Yes
02/09/2026	7.89	24.0	Yes
02/10/2026	7.97	24.0	Yes
02/11/2026	8.04	25.0	Yes
02/12/2026	7.93	24.0	Yes
02/13/2026	7.98	22.5	Yes
02/14/2026	7.98	24.0	Yes
02/15/2026	7.95	22.5	Yes
02/16/2026	7.91	24.0	Yes
02/17/2026	7.91	21.8	Yes
02/18/2026	7.93	23.5	Yes
02/19/2026	7.97	22.0	Yes
02/20/2026	7.94	24.0	Yes
02/21/2026	7.97	23.0	Yes
02/22/2026	7.91	23.0	Yes
02/23/2026	7.96	23.0	Yes
02/24/2026	7.92	21.0	Yes
02/25/2026	7.85	20.3	Yes
02/26/2026	7.93	19.5	Yes
02/27/2026	7.97	20.5	Yes
02/28/2026	7.86	20.0	Yes

Number of excursions this month = 0

Number of excursions last 5 months = 0

Is System in Compliance? Y N

Supervisor's Signature _____ Print Name Dave Trotter

Certification #: 058778 Phone (503) 635-0394 03-Mar-26