

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.6	30			y
4					
5					
6					
7					
8					
9	7.6	25			y
10					
11					
12	7.8				y
13					
14					
15	7.7				y
16					
17					
18	7.6				y
19					
20					
21	7.7	25			y
22					
23					
24	7.4				
25					
26					
27	7.7	30			y
28					
29					
30	7.5				y
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: March 2024
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH

7.2

 Alk

25.0

 (Alkalinity)

Print Name: Sheila H. Wahl

Signature: Sheila H. Wahl

Date & Phone#: 8 April 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's

0
