

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	-				
2	7.6	30			y
3					
4					
5	7.5	30			y
6					
7					
8					
9	7.3				y
10					
11	7.7				y
12					
13					
14	7.6	25			y
15					
16					
17	7.3				y
18					
19					
20	7.7	25			y
21					
22					
23	7.6				y
24					
25					
26	7.4	30			y
27					
28					
29	7.5				y
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: MAY 2024
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Well # 2

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk 25.0 (Alkalinity)

Print Name: Sheila H Wahl
 Signature: Sheila H. Wahl
 Date & Phone#: 6/7/24 971-998-6481

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0