

Day	pH	Alk	Phos	Other	Y/N
1	7.7	30		W <sub>2</sub>	y
2					y
3					
4	7.6				y
5					y
6	7.5				y
7	7.5	30			y
8	7.6				y
9					
10	7.4				y
11					y
12					
13	7.7	25			y
14					y
15					
16	7.6				y
17					y
18					
19	7.6	30			y
20					
21					
22	7.3				y
23					
24					
25	7.8	30			y
26					
27					
28	7.3			▼	y
29					y
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4105086**

**POLEHN HEIGHTS WATER ASSN**

Sample period: June 2024  
 Month/Year

Number of excursions during this month: \_\_\_\_\_

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.2
Alk	25.0 (Alkalinity)

Print Name: Sheila H. Wahl

Signature: Sheila H. Wahl

Date & Phone#: 8 July 2024 971-998-6481

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0