

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.2				y
4					y
5					
6		30			y
7					
8					
9					
10					
11					
12	7.1	20			N
13					
14					
15					
16					
17					
18					
19					
20					
21	7.1				N
22					
23					
24	7.2	35			y
25					
26					
27	7.6				y
28					
29					
30		30			y
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4105086**

**POLEHN HEIGHTS WATER ASSN**

Sample period: August 2024  
 Month/Year

Well #1

Number of excursions during this month: 2

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH	7.2
Alk	25.0 (Alkalinity)

Print Name: Sheila H. Wahl

Signature: Sheila H. Wahl

Date & Phone#: August 30, 2024

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 2