

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.2	30			y
3					
4					
5	7.4				y
6					y
7					
8	7.7	30			y
9					y
10					
11					
12	7.3				y
13					y
14	7.7	25			y
15					y
16					
17	7.5				y
18					y
19					
20	7.3	30			y
21					y
22					
23					
24	7.4				y
25					y
26	7.6	30			y
27					y
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: February 2025
Month/Year

Well #2

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 25.0 (Alkalinity)

Print Name: Sheila H Wahl
Signature: Sheila H. Wahl
Date & Phone#: 3-6-25 971-998-6481

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0