

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	7.6				y
2					
3		30			y
4	7.5				y
5					
6					
7	8.0				y
8					
9		25			y
10	7.5				y
11					
12					
13	7.6				y
14					
15		25			y
16	7.8				y
17					
18					
19	7.4				y
20					
21		25			y
22	7.5				y
23					
24					
25	7.7				y
26					
27		30			y
28	7.3				y
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4105086**

**POLEHN HEIGHTS WATER ASSN**

Sample period: March-2025- Well #2  
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).  
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2  
Alk 25.0 (Alkalinity)

Print Name: Jeremy Tower  
Signature: Tower  
Date & Phone#: 4.9.25 / 503.806.4734

Send to DWP within 10 days after end of  
sampling period

(No = N = Excursion) Total N's 0