

Day	pH	Alk	Phos	Other	Y/N
1					
2		30			y
3	7.4				y
4					
5					
6	7.6				y
7					
8		30			x
9	7.8				y
10					
11					
12	7.6				y
13					
14		25			y
15	7.7				y
16					
17					
18	7.7				y
19					
20		25			y
21	7.7				y
22					
23					
24	7.6				y
25					
26	7.7	30			y
27					
28					
29	7.7				y
30					
31	7.6				y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: May-2025-Well#2
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 25.0 (Alkalinity)

Print Name: Jeremy Tower
Signature: [Signature]
Date & Phone#: 6.3.25 / 503.806.4734

Send to DWP within 10 days after end of
sampling period