

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	7.6				y
5					
6	7.7				y
7					
8					
9					
10	7.8				y
11					
12	7.7				y
13					
14					
15					
16	7.6				y
17					
18	7.8				y
19					
20					
21	7.9				y
22	8.3				y
23	8.7				y
24	7.6				y
25	7.2				y
26	7.2				y
27	7.2				y
28	7.2				y
29	7.3				y
30	7.2				y
31	7.4				y

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: June 2025 - Well #2 until 6.23.25
Month/Year Well #1 from 6.23.25 on



Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality
Parameter(s) as set by State:

pH 7.2
Alk 25.0 (Alkalinity)

Print Name: Jeremy Tower
Signature: Tower
Date & Phone#: 7.2.25 / 503-806-4739

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0