

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.4	25			y
2	7.8				y
3					
4	8.8				y
5	8.3				y
6	8.4				y
7		40			y
8	8.3				y
9					
10	8.5				y
11					
12	7.5				y
13		40			y
14	7.4				y
15					
16	7.4				y
17					
18					
19	8.4	40			y
20	8.8				y
21					
22	8.5				y
23	8.3				y
24	7.9				y
25		30			y
26	7.5				y
27					
28	7.5				y
29					
30	7.5				y
31		25			y

(No = N = Excursion) **Total N's** 0

<<Have
minimums
been met for
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: July-2025-Well#1
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 25.0 (Alkalinity)

Print Name: Jeremy Tower
Signature: J Tower
Date & Phone#: 8.8.2025/503 806 4734

Send to DWP within 10 days after end of
sampling period