

Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.5	30			Y
2					
3	7.5				Y
4					
5	7.4				Y
6					
7	7.9	25			Y
8					
9	8.2				Y
10					
11	8.0				Y
12					
13	7.8	25			Y
14					
15	8.0				Y
16					
17	8.0				Y
18					
19	7.6	25			Y
20					
21	7.4				Y
22					
23	7.3				Y
24					
25	7.3	25			Y
26					
27	7.6				Y
28					
29	7.3				Y
30					
31	7.5	25			Y

<<Have
minimums
been met for
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: Aug-2025-Well #1
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 25.0 (Alkalinity)

Print Name: Jeremy Towler
Signature: Towler
Date & Phone#: 9-3-2025 / 503-806-4734

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0