

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.5				y
3					
4	7.2				y
5	7.5				y
6	7.5	25			y
7					
8	7.5				y
9					
10	7.5				y
11					
12	7.6	25			y
13					
14	7.5				y
15					
16	7.4				y
17	7.5				y
18	7.5	25			y
19					
20	7.4				y
21					
22	7.4				y
23					
24	7.5	25			y
25					
26	7.5				y
27					
28	7.3				y
29					
30	7.5	25			y
31					

<<Have
minimums
been met for
this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: Sept-2025-Well#1
Month/Year

Number of excursions during this month: 0
(Over 9 excursions in 6 months is a violation. Entry
Point and Distribution excursions are cumulative).
An 'excursion' is any day in which the water quality
parameter(s) fall below the minimum set by the
State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 25.0 (Alkalinity)

Print Name: Jeremy Tower
Signature: Tower
Date & Phone#: 10-1-2025/503-806-4734

Send to DWP within 10 days after end of
sampling period

(No = N = Excursion) Total N's 0