



Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3	7.7	30			y
4					
5					
6	7.6				y
7					
8					
9	7.7	30			y
10					
11					
12	7.6				y
13					
14					
15	7.7	25			y
16					
17					
18	7.7				y
19					
20					
21	7.6	25			y
22					
23					
24	7.7				y
25					
26					
27	7.6	30			y
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4105086**

**POLEHN HEIGHTS WATER ASSN**

Sample period: Feb - 2026 - Well #2  
 Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality Parameter(s) as set by State:**

pH 7.2  
 Alk 25.0 (Alkalinity)

Print Name: Jeremy Tower  
 Signature: *Jeremy Tower*  
 Date & Phone#: 3-9-26 / 503-806-4734

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0