



Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Other | Y/N |
|-----|-----|-----|------|-------|-----|
| 1 | | | | | |
| 2 | 7.7 | | | | y |
| 3 | | | | | |
| 4 | | | | | |
| 5 | 7.7 | 25 | | | y |
| 6 | | | | | |
| 7 | | | | | |
| 8 | 7.7 | | | | y |
| 9 | | | | | |
| 10 | | | | | |
| 11 | 7.8 | 30 | | | y |
| 12 | | | | | |
| 13 | | | | | |
| 14 | 7.7 | | | | y |
| 15 | | | | | |
| 16 | | | | | |
| 17 | 7.7 | 30 | | | y |
| 18 | | | | | |
| 19 | | | | | |
| 20 | 7.8 | | | | y |
| 21 | | | | | |
| 22 | | | | | |
| 23 | 7.7 | 30 | | | y |
| 24 | | | | | |
| 25 | | | | | |
| 26 | 7.7 | | | | y |
| 27 | | | | | |
| 28 | | | | | |
| 29 | 7.7 | 30 | | | y |
| 30 | | | | | |
| 31 | | | | | |

<<Have minimums been met for this day?

County: Clackamas Agency: CLACKAMAS COUNTY

ENTRY POINT
EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN

Sample period: March-2026-Well#2
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
 Alk 25.0 (Alkalinity)

Print Name: Jeremy Towler
 Signature: J. Towler
 Date & Phone#: 4.26 / 503-806-4734

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0