



Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Sili	Y/N
4/9	7.5				y
4/18	7.4				y
4/27	7.4				y
4/30		35			

<<Have minimums been met for this day?

County: Clackamas Agency: Clack

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN.

Sample period: APRIL 2021
Month/Year

Well #2

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Sheila H. Wahl

Signature: Sheila H. Wahl

Date: 8 May 2021

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) Total N's 0



21229 S. Richard Court
Oregon City, OR 97045

7 May 2021

DWP.DMCE@dhsosha.state.or.us
DHS Drinking Water Program
P. O. Box 14350
Portland, OR 97293-0350

RE: PWS #OR 41-05086 - Lead & Copper Rule Corrosion Control

Dear Sir:

Enclosed is the Lead & Copper Rule Corrosion Control report for the month of May 2021.

Sincerely,

Sheila H. Wahl Consulting, LLC
System Operations Manager
For Polehn Heights Water Association, Inc.
503-631-3036

2020-2021 Board of Directors

Harlan Barcus, Chairman	503.631.7275
Allie Wadsworth, Secretary	503.577.7208
Theresa Castor, Treasurer	503.631.2677
Scott Ray, Director	503.475.2283
Janet Tankersley, Director	503.545.2229
Sheila Wahl, System Operations Manager	971-998-6481