Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

DHS oregon department of human services

Day	pH	Alk	Phos	Sili	Y/N
12/2	7.3				y
12/5	7.4				y
12/8	7.2				y
12/14	7.6				y
12/17	7.4				y
12/23	7.6				y
12/26	7.4				y
1/1/22		30			
	Well #2				

(No = N = Excursion) **Total N's** 0

<<Have minimums been met for this day?

County: Clackamas Agency: Clack

ENTRY POINT

EP-A

PWS ID 4105086

POLEHN HEIGHTS WATER ASSN.

Sample period: December 2021
Month/Year

Number of excursions during this month: 0

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Well #2

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Print Name: Sheila H. Wahl

Signature: Sheila H. Wahl

Date: 1-9-22

Send to DWP within 10 days after end of sampling period

DHS, Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone: (503) 731-4381 Website: wwww.ohd.hr.state.or.us/dwp