

Lead & Copper Rule Corrosion Control

Day	рΗ	Alk	Phos	Other	Y/N	<-Have ENTRY POINT
1						
2						been met for EP-A this day?
3						PWS ID 4105308
4						Oxberg Water Service
5						Sample Period: March 2022
6	7.4				Y	
7						Month/Year
8						Number of excursions* during this month: <u>0</u>
9						(Count the number of days when any WQP was
10						less than the minimum required)
11						
12						
13	7.4				Y	
14						
15						For OHA use only
16						
17						Minimum Water Quality
18						Parameters as set by
19						pH 7.2
20	7.4				Y	Alk (Alkalinity)
21						
22						
23						
24						
25						
26						
27						Print Name: Matt Olson
28	7.4				Y	Signature: Muttelle
29						Signature: <u>Mutt Obser</u> Date: <u>4-7-2022</u>
30						
31						Send to DWP within 10 days after end of sampling period
(No = N	N = Exc	cursion) Tota	I N's	0	

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/