

Lead & Copper Rule Corrosion Control

Day	рΗ	Alk	Phos	Other	Y/N	<-Have ENTRY POINT
1						
2						been met for EP-A this day?
3						PWS ID 4105308
4						Oxberg Water Service
5	7.4				Y	Sample Period: August 2022
6						Sample Period:August 2022
7						
8						Number of excursions* during this month: <u>0</u>
9						(Count the number of days when any WQP was
10						less than the minimum required)
11						
12	7.4				Y	
13						
14						
15						For OHA use only
16						
17						Minimum Water Quality
18						Parameters as set by
19	7.3				Y	pH 7.2
20						Alk (Alkalinity)
21						
22						
23						
24						
25						
26	7.6				Y	
27						Print Name: Matt Olson
28						Signature: Matt Ologie
29						Signature:
30						
31						Send to DWP within 10 days after end of sampling period
(No = N = Excursion) Total N's 0						

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/