

Day	pH	Alk	Phos	Other	Y/N
1					
2	7.6				Y
3					
4					
5					
6					
7					
8					
9	7.7				Y
10					
11					
12					
13					
14					
15					
16	7.3				Y
17					
18					
19					
20					
21					
22	7.5				Y
23					
24					
25					
26					
27					
28					
29					
30	7.5				Y
31					

<<Have minimums been met for this day?

ENTRY POINT
 EP-A
 PWS ID 4105308
 Oxberg Water Service

Sample Period: November 2022
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 Alk *(Alkalinity)*

Print Name: Matt Olson
Signature: *Matt Olson*
Date: 12-6-2022

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0