

# Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
7		7.6				Y
14		7.6				Y
21		7.6				Y
28		7.5				Y
(N = No = Excursion) <b>Total N's</b>						0

<Has sample met the minimums? **ENTRY POINT A**

PWS ID: 41

System Name: Oxberg Water

Sample Period: March 2023

Number of excursions during this Sample Period = 0

(Number of locations when any WQP was less than the minimum.)

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<input type="text" value="7.2"/>	
Alk	<input type="text"/>	(Alkalinity)
PO4	<input type="text"/>	(Orthophosphate)
Other	<input type="text"/>	(_____)

Print Name: JJ Olson

Signature: *Jeffrey Olson*

Date: 04/03/2023

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>