

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	Sample Location (Other than Entry Point)	рН	Alk	PO4	other	Y/N	<has sample<="" th=""></has>
		7.4				Y	ENTRY POINT A
		7.4				Y	minimums?
)		7.3				Y	
	7.	7.3	3		Y	Y	PWS ID: 41 0 5 3 0 8
							System Name: <u>Oxberg Water</u>
	(N = No = Excu	= Excursion) Total N's			5	0	Sample Period: <u>December 2023</u>
							Number of excursions during this
							Sample Period = <u>0</u>
		(Number of locations when any WQP was less than the minimum.)					
							Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to ge total for sample period.
							For OHA use only
							Minimum Water Quality Parameters as set by
							pH 7.2
							Alk (Alkalinity)
							PO4 (Orthophosphate)
							Other ()
							Print Name: <u>JJ Olson</u>

 Print Name: JJ Olson

 Signature: Jeffrey Olson

 Date: 01/09/2024

Send to Drinking Water Program within 10 days after end of sampling period: OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/