

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	Sample Location (Other than Entry Point)	pH	Alk	PO4	other	Y/N
6		7.6				Y
13		7.6				Y
20		7.6				Y
27		7.5				Y
						Y
(N = No = Excursion)      Total N's						0

<Has sample met the minimums?      **ENTRY POINT A**

PWS ID: 41 0 5 3 0 8

System Name: Oxberg Water

Sample Period: February 2024

**Number of excursions during this Sample Period = 0**

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	7.2	
Alk		<i>(Alkalinity)</i>
PO4		<i>(Orthophosphate)</i>
Other		<i>(_____)</i>

Print Name: JJ Olson

Signature: *Jeffrey Olson*

Date: 03/09/2024

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405    Website: <http://healthoregon.org/dwp/>