

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

| Day                                 | Sample Location (Other than Entry Point) | pH   | Alk | PO4 | other | Y/N |
|-------------------------------------|------------------------------------------|------|-----|-----|-------|-----|
| 4                                   |                                          | 7.26 |     |     |       | Y   |
| 18                                  |                                          | 7.27 |     |     |       | Y   |
|                                     |                                          |      |     |     |       |     |
|                                     |                                          |      |     |     |       |     |
| (N = No = Excursion)      Total N's |                                          |      |     |     |       | 0   |

<Has sample met the minimums?

**ENTRY POINT A**

PWS ID: 41 0 5 3 0 8

System Name: Oxberg Water

Sample Period: OCT 2025

Every 2 weeks

Number of excursions during this Sample Period = 0

*(Number of locations when any WQP was less than the minimum.)*

*Note: Entry Point and Distribution Excursions are cumulative. Add Entry Point and Distribution Excursions to get total for sample period.*

*For OHA use only*

### Minimum Water Quality Parameters as set by

pH 7.2

Alk  *(Alkalinity)*

PO4  *(Orthophosphate)*

Other  *(\_\_\_\_\_)*

Print Name: Curtis Olson

Signature: Curtis Olson

Date: 11/10/2025

Send to Drinking Water Program within 10 days after end of sampling period:  
 OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>