

Day	pH	Alk	Phos	Other	Y/N
1	7.3	70			Y
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16	7.5	70			Y
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					

<<Have minimums been met for this day?

County: Curry    Agency: CURRY COUNTY

### ENTRY POINT

#### EP-A

#### PWS ID 4105860

#### OLD SHEEP RANCH WATER ASSOC

**Sample period:** February, 2021  
*Month/Year*

**Number of excursions during this month:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

#### Reference

#### Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
 Alk 65.0 (Alkalinity)

**Print Name:** Jean J. Ochsner, DRC

**Signature:** *Jean J. Ochsner*

**Date & Phone#:** 02/16/2021 // 503-702-5823

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0