

Water Quality Parameter Monitoring Form  
**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Other	Y/N
1	Last tested December 26, 2021				
2					
3					
4					
5					
6					
7					
8					
9	7.4	75			Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	7.5	70			Y
24					
25					
26					
27					
28					
29					
30					
31					

<<Have  
minimums  
been met for  
this day?

County: Curry

Agency: CURRY COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4105860**

**OLD SHEEP RANCH WATER ASSOC**

**Sample period:** January, 2022  
Month/Year

**Number of excursions during this month:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

**Minimum Water Quality  
Parameter(s) as set by State:**

pH 7.2  
Alk 65.0 (Alkalinity)

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

**Print Name:** Jean J. Ochsner, DRC

**Signature:** Jean J. Ochsner

**Date & Phone#:** 01/23/2022 // 503-702-5823

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0