

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1					
2					
3					
4	Last tested October 30 , 2022				
5					
6					
7					
8					
9					
10					
11					
12					
13	7.3	75			Y
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27	7.3	75			Y
28					
29					
30					
31					

<<Have
minimums
been met for
this day?

County: Curry

Agency: CURRY COUNTY

ENTRY POINT

EP-A

PWS ID 4105860

OLD SHEEP RANCH WATER ASSOC

Sample period: November, 2022
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH 7.2
Alk 65.0 (Alkalinity)

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

Print Name: Mark A. Ochsner, DRC

Signature: Mark Ochsner

Date & Phone#: 11/29/2022 (503-501-7553)

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0