

Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Last tested March 19, 2023				
2	7.2	75			Y
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16	7.4	80			Y
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30	7.4	80			Y
31					

<<Have minimums been met for this day?

County: Curry Agency: CURRY COUNTY

ENTRY POINT
EP-A

PWS ID 4105860

OLD SHEEP RANCH WATER ASSOC

Sample period: April, 2023
Month/Year

Number of excursions during this month: _____

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

Minimum Water Quality Parameter(s) as set by State:

pH 7.2
Alk 65.0 (*Alkalinity*)

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

Print Name: Mark A. Ochsner, DRC

Signature: *Mark Ochsner*

Date & Phone#: 04/30/2023 / 503-501-7553

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0