

# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Last tested October 29, 2023				
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12	7.4	80			Y
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26	7.5	80			Y
27					
28					
29					
30					
31					

<<Have minimums been met for this day?
County: Curry Agency: CURRY COUNTY

### ENTRY POINT

#### EP-A

#### PWS ID 4105860

#### OLD SHEEP RANCH WATER ASSOC

**Sample period:** November, 2023  
*Month/Year*

**Number of excursions during this month:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

*Reference*

#### Minimum Water Quality Parameter(s) as set by State:

pH 7.2

Alk 65.0 *(Alkalinity)*

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

**Print Name:** Mark A. Ochsner, DRC

**Signature:** *Mark Ochsner*

**Date & Phone#:** 11/28/2023 / 503-501-7553

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0