



# Water Quality Parameter Monitoring Form Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	Last tested March 31, 2024				
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14	7.4	75			Y
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28	7.3	80			Y
29					
30					
31					

<<Have minimums been met for this day?

County: Curry Agency: CURRY COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4105860**

**OLD SHEEP RANCH WATER ASSOC**

**Sample period:** April 28, 2024  
Month/Year

**Number of excursions during this month:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

**Reference**

**Minimum Water Quality Parameter(s) as set by State:**

pH **7.2**  
Alk **65.0** (Alkalinity)

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

**Print Name:** Mark A. Ochsner, DRC

**Signature:** *Mark Ochsner*

**Date & Phone#:** 4/28/2024 / 503-501-7553

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** **0**