



# Water Quality Parameter Monitoring Form

## Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1	7.3	75			Y
2					
3	Last tested August 18, 2024				
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15	7.4	80			Y
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29	7.3	75			Y
30					
31					

<<Have minimums been met for this day?

County: Curry Agency: CURRY COUNTY

### ENTRY POINT

### EP-A

### PWS ID 4105860

### OLD SHEEP RANCH WATER ASSOC

**Sample period:** September 2024  
Month/Year

**Number of excursions during this month:** \_\_\_\_\_

*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.*

#### Reference

#### Minimum Water Quality Parameter(s) as set by State:

pH 7.2  
Alk 65.0 (Alkalinity)

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

**Print Name:** Mark A. Ochsner, DRC

**Signature:** Mark Ochsner

**Date & Phone#:** 9/29/2024 / 503-501-7553

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** 0