

Water Quality Parameter Monitoring Form
Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Other	Y/N
1				Last tested October 26, 2025	
2					
3					
4					
5					
6					
7					
8					
9	7.4	75			Y
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23	7.3	75			Y
24					
25					
26					
27					
28					
29					
30					
31					

(No = N = Excursion) **Total N's**

<<Have
minimums
been met for
this day?

County: Curry Agency: CURRY COUNTY

ENTRY POINT

EP-A

PWS ID 4105860

OLD SHEEP RANCH WATER ASSOC

Sample period:
Month/Year

Number of excursions during this month:

(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative). An 'excursion' is any day in which the water quality parameter(s) fall below the minimum set by the State.

Reference

**Minimum Water Quality
Parameter(s) as set by State:**

pH	7.2
Alk	65.0 (Alkalinity)

For every 1 gallon of well water added to the mixing tank, 0.75 pounds of soda ash is added, for a ratio of 0.75.

Print Name:

Signature:

Date & Phone#:

Send to DWP within 10 days after end of sampling period