

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.74			
2	7.70			
3	7.54			
4	7.75	51.0	1.2	
5	7.75			
6	7.50			
7	7.65			
8	7.68			
9	7.64			
10	7.90			
11	8.50	52.2	1.5	
12	8.33			
13	7.88			
14	7.50			
15	7.40			
16	7.45			
17	7.63			
18	7.49	48.0	1.3	
19	7.57			
20	7.70			
21	7.79			
22	7.48			
23	7.80			
24	7.80			
25	8.00	60.0	1.2	
26	8.10			
27	7.98			
28	7.98			
29	7.86			
30	7.46			
31	7.41			

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**  
**Sample Period: January / 2021**  
*Month/Year*

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 

7.2
-----

  
 PO4 

0.5
-----

 (Orthophosphate)

**Print Name: Terry Force**  
**Signature: [Signature]**  
**Date: 2-4-21 503-455-3331**

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

0
---