

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.59	62	1.1	
2	7.55			
3	7.51			
4	7.55			
5	7.57			
6	7.63			
7	7.41			
8	7.45	45	1.1	
9	7.59			
10	7.68			
11	7.49			
12	7.55			
13	7.50			
14	7.60			
15	7.70			
16	7.60			
17	7.67			
18	7.78	60	0.9	
19	7.44			
20	7.52			
21	7.52			
22	7.74			
23	7.49			
24	7.62			
25	7.56			
26	7.49			
27	7.53			
28	7.59	50	1.1	

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: February / 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH


7.2

PO4

0.5

 (Orthophosphate)

Print Name: Terry Force

Signature: 

Date: 3/1/21 503-455-3331

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's**

0
