

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Y/N
1	7.59	50	1.19	
2	7.90			
3	7.62			
4	7.61			
5	7.67			
6	7.67			
7	7.54			
8	7.54	57	1.3	
9	7.94			
10	8.00			
11	7.60			
12	7.43			
13	7.65			
14	7.65			
15	7.61	64	1.6	
16	7.44			
17	7.77			
18	7.75			
19	7.62			
20	7.56			
21	7.56			
22	7.55			
23	7.55			
24	7.40	65	1.4	
25	7.52			
26	7.56			
27	7.48			
28	7.51			
29	7.47			
30	7.53			
31	7.62	66	1.3	

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**

**Sample Period: March / 2021**  
*Month/Year*

**Number of excursions\* during this month: 0**  
(Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0**  
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH 7.2

PO4 0.5 (Orthophosphate)

**Print Name: Terry Force**  
**Signature: [Signature]**  
**Date: 4/1/21 503-455-3331**

Send to DWP within 10 days after end of sampling period

(No = N = Excursion) **Total N's** **0**