



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.70			
2	7.70			
3	7.73			
4	7.55			
5	7.55	68	1.22	
6	7.80			
7	7.69			
8	7.70			
9	7.70			
10	7.70			
11	7.79			
12	7.80	68	1.66	
13	7.66			
14	7.80			
15	7.90			
16	7.80			
17	7.55			
18	7.50			
19	7.59	62	1.63	
20	7.62			
21	7.54			
22	7.55			
23	7.63			
24	7.43			
25	7.44			
26	7.51	62	1.44	
27	7.48			
28	7.50			
29	7.45			
30	7.53			

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT
EP-A**

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: April / 2021
Month/Year

Number of excursions* during this month: 0
(Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0
(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

PO4 0.5 (Orthophosphate)

Print Name: Terry Force

Signature: 

Date: 5/3/2021 503-455-3333

Send to DWP within 10 days after end of sampling period

Total N's **0**

(No = N = Excursion)