



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.48			
2	7.47			
3	7.50			
4	7.63			
5	7.43			
6	7.55			
7	7.75	53	1.36	
8	7.63			
9	7.38			
10	7.41			
11	7.44			
12	7.43	54	1.25	
13	7.50			
14	7.75			
15	7.61			
16	7.66			
17	7.44			
18	7.59			
19	7.55	53	1.19	
20	7.64			
21	7.44			
22	7.24			
23	7.55			
24	7.60			
25	7.50			
26	7.63	52.9	0.72	
27	7.58			
28	7.63			
29	7.50			
30	7.69			
31	7.68			
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416
Georgia-Pacific CLCP Wauna

Sample Period: July / 2021
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	(Orthophosphate)
PO4	0.5	

Print Name: Terry Force

Signature: 

Date: 8-2-21

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>