



Water Quality Parameter Monitoring Form

Lead & Copper Rule Corrosion Control

| Day | pH | Alk | Phos | Y/N |
|----------------------|------|------|------|----------|
| 1 | 7.71 | | | |
| 2 | 7.83 | | | |
| 3 | 7.81 | | | |
| 4 | 7.73 | | | |
| 5 | 7.75 | | | |
| 6 | 7.73 | | | |
| 7 | 7.65 | | | |
| 8 | 7.68 | 58.7 | 1.28 | |
| 9 | 7.75 | | | |
| 10 | 7.71 | | | |
| 11 | 7.65 | | | |
| 12 | 7.58 | | | |
| 13 | 7.77 | 59.6 | 1.25 | |
| 14 | 7.79 | | | |
| 15 | 7.65 | | | |
| 16 | 7.65 | | | |
| 17 | 7.65 | | | |
| 18 | 7.61 | | | |
| 19 | 7.52 | | | |
| 20 | 7.54 | 59.7 | 1.38 | |
| 21 | 7.62 | | | |
| 22 | 7.62 | | | |
| 23 | 7.55 | | | |
| 24 | 7.62 | | | |
| 25 | 7.66 | | | |
| 26 | 7.69 | | | |
| 27 | 7.71 | | | |
| 28 | 7.72 | | | |
| 29 | 7.71 | | | |
| 30 | 7.67 | | | |
| 31 | | | | |
| (No = N = Excursion) | | | | 0 |
| TOTAL N'S | | | | |

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416
Georgia-Pacific CLCP Wauna
Sample Period: September 2021
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)


For OHA use only

Minimum Water Quality Parameters as set by

pH
PO4 (Orthophosphate)

| |
|-----|
| 7.2 |
| 0.5 |

Print Name: Terry Force

Signature: 

Date: 10-1-2021

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>