

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.5			Y
2	7.5			Y
3	7.6			Y
4	7.6	58.0	1.32	Y
5	7.5			Y
6	7.4			Y
7	7.6			Y
8	7.6			Y
9	7.6			Y
10	7.6			Y
11	7.7	60.2	1.16	Y
12	7.7			Y
13	7.7			Y
14	7.7			Y
15	7.8			Y
16	7.8			Y
17	7.7			Y
18	7.8	60.9	1.16	Y
19	7.8			Y
20	7.8			Y
21	7.8			Y
22	7.7			Y
23	7.8			Y
24	7.7			Y
25	7.7	61.3	1.39	Y
26	7.7			Y
27	7.7			Y
28	7.8			Y
29	7.4			Y
30	7.5			Y
31	7.6			Y
(No = N = Excursion)				<b>0</b>
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop      Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**

**Georgia-Pacific CLCP Wauna**

**Sample Period: October 2021**  
*Month/Year*

**Number of excursions\* during this month: 0** (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0** (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH

PO4 (Orthophosphate)

<b>7.2</b>
<b>0.5</b>

Print Name: Terry Force

Signature:

Date: 11-3-21

Phone: 503-455-2600

**Send to DWP within 10 days after end of sampling period**

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>