



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Y/N
1	7.62			Y
2	7.62			Y
3	7.61			Y
4	7.64			Y
5	7.55			Y
6	7.63	60.2	1.36	Y
7	7.66			Y
8	7.65			Y
9	7.68			Y
10	7.68			Y
11	7.73			Y
12	7.51			Y
13	7.52	54.0	1.34	Y
14	7.63			Y
15	7.65			Y
16	7.61			Y
17	7.61			Y
18	7.56			Y
19	7.56			Y
20	7.53			Y
21	7.48			Y
22	7.50	50.7	1.35	Y
23	7.57			Y
24	7.56			Y
25	7.50			Y
26	7.37			Y
27	7.53			Y
28	7.39			Y
29	7.38			Y
30	7.64			Y
31	7.64			Y
(No = N = Excursion)				<b>0</b>
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**  
**Sample Period: December 2021**  
*Month/Year*

Number of excursions\* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

(pH) (Orthophosphate)

7.2
0.5

Print Name: Terry Force

Signature:

Date: 1-10-22

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period  
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350  
Phone (971) 873-0405 Website: <http://healthoregon.org/dwp/>

*Mob*