



Water Quality Parameter Monitoring Form

# Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.68			Y
2	7.72			Y
3	7.63			Y
4	7.62			Y
5	7.74			Y
6	7.75			Y
7	7.76	64.7	1.40	Y
8	7.77			Y
9	7.79			Y
10	7.78			Y
11	7.85			Y
12	7.72			Y
13	7.69			Y
14	7.57	65.8	3.19	Y
15	7.60			Y
16	7.70			Y
17	7.84			Y
18	7.78			Y
19	7.79			Y
20	7.85			Y
21	7.68			Y
22	7.71	65.5	1.36	Y
23	7.70			Y
24	7.79			Y
25	7.79			Y
26	7.64			Y
27	7.68			Y
28	7.67			Y
29				
30				
31				
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**  
**Sample Period: February 2022**  
*Month/Year*

Number of excursions\* during this month: 0 (Count the number of days when any WQP was less than the minimum required)


Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

For OHA use only

**Minimum Water Quality Parameters as set by**

pH 7.2  
 PO4 0.5 (Orthophosphate)

Print Name: Terry Force

Signature: 

Date: 3-2-2022

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>