



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Y/N
1	7.67			Y
2	7.47			Y
3	7.50			Y
4	7.90			Y
5	7.90			Y
6	7.61			Y
7	7.74	54.7	1.35	Y
8	7.40			Y
9	7.78			Y
10	7.24			Y
11	7.75			Y
12	7.82			Y
13	7.52			Y
14	7.57	61.5	1.62	Y
15	7.71			Y
16	7.60			Y
17	7.57			Y
18	7.48			Y
19	7.55			Y
20	7.62			Y
21	7.62	63.9	1.39	Y
22	7.59			Y
23	7.80			Y
24	7.86			Y
25	7.86			Y
26	7.60			Y
27	7.50			Y
28	7.74	62.4	1.35	Y
29	7.74			Y
30	7.57			Y
31	7.63			Y
(No = N = Excursion)				0
TOTAL N'S				0

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**  
**Sample Period: March 2022**  
*Month/Year*

**Number of excursions\* during this month: 0** (Count the number of days when any WQP was less than the minimum required)

**Total excursions during the previous 5 months: 0** (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH   
PO4  (Orthophosphate)

Print Name: Terry Force

Signature:

Date: 4/4/2022

Phone: 503-455-3331

**Send to DWP within 10 days after end of sampling period**

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>