



Water Quality Parameter Monitoring Form

**Lead & Copper Rule Corrosion Control**

Day	pH	Alk	Phos	Y/N
1	7.6			Y
2	7.6			Y
3	7.6			Y
4	7.4	68.2	1.36	Y
5	7.4			Y
6	7.4			Y
7	7.7			Y
8	7.7			Y
9	7.5			Y
10	7.6			Y
11	7.6	60.7	1.41	Y
12	7.4			Y
13	7.7			Y
14	7.7			Y
15	7.6			Y
16	7.6			Y
17	7.7			Y
18	7.7	58.1	1.40	Y
19	7.6			Y
20	7.4			Y
21	7.5			Y
22	7.5			Y
23	7.6			Y
24	7.6			Y
25	7.6	54.6	1.34	Y
26	7.6			Y
27	7.5			Y
28	7.7			Y
29	7.8			Y
30	7.7			Y
(No = N = Excursion)				0
TOTAL N'S				0

<<Have minimums been met for this day?      County: Clatsop      Agency: CLATSOP COUNTY

**ENTRY POINT**  
**EP-A**

**PWS ID 4190416**  
**Georgia-Pacific CLCP Wauna**  
Sample Period: APRIL 2022  
*Month/Year*

Number of excursions\* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH      7.2

PO4     0.5      (Orthophosphate)

Print Name: Terry Force

Signature: *Terry W Force*

Date: 5-2-2022

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>