



Water Quality Parameter Monitoring Form

### Lead & Copper Rule Corrosion Control

Sample Location	pH	Alk	Phos	Y/N
Utilizing lunchroom Sink (6-13)	7.7	49.5	1.38	Y
Clockroom lunchroom Sink (6-13)	7.6	49.3	1.35	Y
First User (6-13)	7.7	49.6	1.34	Y
Utilizing lunchroom Sink (6-27)	7.5	54.6	1.33	Y
Clockroom lunchroom Sink (6-27)	7.7	53.7	1.34	Y
First User (6-27)	7.6	54.8	1.34	Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this

County: Clatsop Agency: CLATSOP COUNTY

**ENTRY POINT**

**EP-A**

**PWS ID 4190416**

**Georgia-Pacific CLCP Wauna**

**Sample Period: June / 2022**

**Number of excursions\* during this month: 0**  
*(Count the number of days when any WQP was less than the minimum required)*

**Total excursions during the previous 5 months: 0**  
*(Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative )*

*For OHA use only*

**Minimum Water Quality Parameters as set by**

pH	<u>7.2</u>	
PO4	<u>0.5</u>	(Orthophosphate)

Print Name: Travis Babikoff

Signature:

Date: 7/6/22

Phone: 503-455-3248

**Send to DWP within 10 days after end of sampling period**