

Lead & Copper Rule Corrosion Control

Table with columns: Day, pH, Alk, Phos, Y/N. Rows 1-28 containing daily monitoring data.

Entry Point Form: <<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY ENTRY POINT EP-A PWS ID 4190416 Georgia-Pacific CLCP Wauna Sample Period: February 2023 Month/Year

Number of excursions\* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2 PO4 0.5 (Orthophosphate)

Print Name: Terry Force Signature: [Signature] Date: 3-1-2023 Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: http://healthoregon.org/dwp/

(No = N = Excursion)0

TOTAL N'S