

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.6	64.6	1.33	Y
2	7.7			Y
3	7.8			Y
4	7.6			Y
5	7.6			Y
6	7.5			Y
7	7.6			Y
8	7.6	64.3	1.32	Y
9	7.5			Y
10	7.7			Y
11	7.7			Y
12	7.7			Y
13	7.4			Y
14	7.5			Y
15	7.5	58.7	1.43	Y
16	7.4			Y
17	7.6			Y
18	7.6			Y
19	7.7			Y
20	7.6			Y
21	7.5			Y
22	7.6	59.1	1.31	Y
23	7.9			Y
24	7.6			Y
25	7.6			Y
26	7.7			Y
27	7.7			Y
28	7.6			Y
29	7.6			Y
30	7.7			Y
31	7.7			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day? County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416
Georgia-Pacific CLCP Wauna
Sample Period: May 2023
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH	7.2	
PO4	0.5	(Orthophosphate)

Print Name: Terry Force

Signature:

Date: 6-2-2023

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period
OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>