

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.4			Y
2	7.8			Y
3	7.8			Y
4	7.7			Y
5	7.8	53.4	1.37	Y
6	7.8			Y
7	7.7			Y
8	7.7			Y
9	7.7			Y
10	7.6			Y
11	7.6			Y
12	7.6	53.2	1.36	Y
13	7.7			Y
14	7.8			Y
15	7.8			Y
16	7.8			Y
17	7.5			Y
18	7.6			Y
19	7.8	53.6	1.43	Y
20	7.8			Y
21	7.7			Y
22	7.6			Y
23	7.7			Y
24	7.8			Y
25	7.6			Y
26	7.5	53.6	1.35	Y
27	7.2			Y
28	7.4			Y
29	7.7			Y
30	7.7			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT
EP-A

PWS ID 4190416
Georgia-Pacific CLCP Wauna

Sample Period: June 2023
Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)

For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2
 PO4 0.5 (Orthophosphate)

Print Name: Terry Force

Signature:

Date: 7-5-23

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>