

Lead & Copper Rule Corrosion Control

Day	pH	Alk	Phos	Y/N
1	7.7			Y
2	7.6			Y
3	7.6	55.5	1.37	Y
4	7.6			Y
5	7.7			Y
6	7.7			Y
7	7.5			Y
8	7.5			Y
9	7.6			Y
10	7.5	55.8	1.27	Y
11	7.4			Y
12	7.5			Y
13	7.5			Y
14	7.6			Y
15	7.5			Y
16	7.5			Y
17	7.5	58.8	1.34	Y
18	7.6			Y
19	8.0			Y
20	7.9			Y
21	7.8			Y
22	7.8			Y
23	7.8			Y
24	7.7	57.9	1.30	Y
25	7.7			Y
26	7.8			Y
27	7.8			Y
28	7.8			Y
29	7.8			Y
30	7.8			Y
31	7.8			Y
(No = N = Excursion)				0
TOTAL N'S				

<<Have minimums been met for this day?

County: Clatsop Agency: CLATSOP COUNTY

ENTRY POINT

EP-A

PWS ID 4190416

Georgia-Pacific CLCP Wauna

Sample Period: July 2023

Month/Year

Number of excursions* during this month: 0 (Count the number of days when any WQP was less than the minimum required)

Total excursions during the previous 5 months: 0 (Over 9 excursions in 6 months is a violation. Entry Point and Distribution excursions are cumulative)


For OHA use only

Minimum Water Quality Parameters as set by

pH 7.2

PO4 0.5 (Orthophosphate)

Print Name: Terry Force

Signature: 

Date: 8-2-2023

Phone: 503-455-3331

Send to DWP within 10 days after end of sampling period

OHA Drinking Water Program, PO Box 14350, Portland, OR 97293-0350 Phone (971) 673-0405 Website: <http://healthoregon.org/dwp/>